



Invoice #16467

20126 Ballinger Way Northeast
Shoreline , Washington 98155
206.856.0757
www.reelroooter.com
reelroooter@gmail.com

Invoiced Date: Oct 4, 2021
Due Date: Oct 4, 2021
Status: Paid

Bill To

Sandra Brenner

(206) 271-7100

Scope
1238 NW 126th St, Seattle, WA, USA
Noah Ziegler

Notes

inspected mainline through exterior cleanout behind pool house, abs line, line holds water from 9ft-35ft, and then 38ft-45ft, and 60ft-70ft, line connects to sidesewer from house at 100ft, camera will not pass due to amount of turns

lifted toilet in basement in house to inspect rest or sewer line, toilet line is abs, left wye at 2ft, concrete line at 19ft, tie in from pool house at 23ft, 6in concrete at 48ft, main city sewer found at 80ft, no breaks or separations found at this time

recommend running plenty of water and limit amount of paper flushed down to keep bellies clear

Items	Unit Price	Quantity	Amount
C1	275.00	1.00	275.00
Sewer Scope			
LT	75.00	1.00	75.00
Lift Toilet			



Subtotal \$ 350.00
Taxable (10.25%) \$ 0.00
Tax Due (10.25%) \$ 0.00

Total \$ 350.00

Amount Paid \$ 350.00
Amount Due \$ 0.00